# SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CHC/AVL/ 86/2024-25

It is certified that an inspection team headed by Sri. Javara H M "Senior Health Inspecting Officer" from Community Health Centre, Avalahalli, inspected the National Public School, Survey No. 92/1, 92/2 & 93, Goravigere Village, Kadugodi Main Road, Bidarahalli Hobli, Bangalore East Taluk, Bengaluru - 560 067, on 24-03-2025 and on the basis of Water Test Report bearing no ULR - TC412225000001086F dated 24-03-2025 of Tattva Analytical laboratories LLP, Bangalore-560048 certified that the National Public School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till: 25-03-2026

H-M. Javara ಹೆಚ್. ಎಂ. ಜವರ

Dated: 26-03-2025

ಹಿರಿಯ ಆರೋಗ್ಯ ನಿರೀಕ್ಷಾಣಾಧಿಕಾ**ಿ** 

Signature with Seal: .... ಸಮೂದಾಯ ಆರೋಗ್ಯ ಕೇಂದ್ರ

ಆವಲಹಳ್ಳಿ, ಬೆಂಗಳೂರು ಪೂರ್ವ ಶಾಲ್ಲೂಕು ಚಿಂಗಳೂರು ನಗರ

Name: Sri. Javara H M

Designation: Senior Health Inspecting Officer

Community Health Centre, Avalahalli

Name & Address of the Office/Department;

To,

National Public School Survey No. 92/1, 92/2 & 93,

Goravigere Village, Kadugodi Main Road,

Bidarahalli Hobli, Bangalore East Taluk,

Bengaluru - 560 067

್ರಾಧಿಕಾರಿಗಳು ುದಾಯ ಆರೋಗ್ಯ ಕೇಂದ್ರ **ಟ್ಟಿಕೆಲಹಳ್ಳಿ, ಬೆಂಗಳೂರು ಪೂರ್ವ ತಾಲ್ದೂಕು** ಟೆಂಗಳೂರು ನಗರ ಜಿಲ್ಲೆ - 560 049



# TATTVA ANALYTICAL LABORATORIES LLP

### (MOEF Recognized & OHSAS Certified as per ISO 45001:2018)

No:118, Plot No: N1, ITI Industrial Estate, Whitefield Road Mahadevapura, Bangalore – 560048 Telephone: 9448613741/9886628620



Email: info.tattvalabs@gmail.com, Website: www.tattvalaboratories.com

TAL/FR/MR/31/00

## **TEST REPORT**

#### ULR - TC412225000001086F

Name of the Organization:		Date of Sampling	N/A
M/S. National Public School		Date of Receipt	20.03.2025
#92, 93, Goravigere colony, Katta	nallur,	Date of Analysis started	20.03.2025
Sannathammanahalli, Goravigere	,	Date of Analysis Completed	24.03.2025
Bangalore - 560067		Date of Report	24.03.2025
		Sample drawn by	Customer
		Source of collection	N/A
Sample Code	TAL/2025/S – 1086	Sampling container	Polythene bottle
Nature of Sample	Water	Environmental condition	N/A
Sample Description	Drinking water	Sampling method	N/A
Sample condition when received	Ok	Sampling Quantity	1.0 Ltr

#### **RESULTS**

SI.No	Parameters	Units	Protocol	Results	Standards IS: 10500:2012			
					Acceptable Limits	Permissible Limits		
1	pH	-	IS:3025 PART 11	6.78	6.5 to 8.5	No Relaxation		
2	Odour	-	IS:3025 PART 05	Agreeable	Agreeable	Agreeable		
3	Turbidity	NTU	IS:3025 PART 10	0.1	1	5		
4	Total dissolved solids	mg/l	IS:3025 PART 16	72.0	500	2000		
5	Total Hardness	mg/l	IS:3025 PART 21	29.4	200	600		
6	Calcium as Ca	mg/l	IS:3025 PART 40	6.2	75	200		
7	Magnesium as mg	mg/l	IS:3025 PART 46	3.3	30	100		
8	Alkalinity as CaCO <sub>3</sub>	mg/l	IS:3025 PART 23	25.0	200	600		
9	Chlorides as Cl	mg/l	IS:3025 PART 32	28.5	250	1000		
10	Sulphates as SO <sub>4</sub>	mg/l	IS:3025 PART 24	10.6	200	400		
11	Iron as Fe	mg/l	IS:3025 PART 53	BDL (DL - 0.1)	0.3	No Relaxation		
12	Fluorides as F	mg/l	IS:3025 PART 60	0.1	1.0	1.5		
13	Nitrates as NO₃	mg/l	IS:3025 PART 34	2.1	45	No Relaxation		
14	Boron as B	mg/l	IS:3025 PART 57	BDL (DL - 0.1)	0.5	1.0		
Microb	Microbiological Parameters							
15	E. coli	Per 100 ml	IS:15185 - 2016	Absent	SND	SND		
16	Total Coliforms Count	Per 100 ml	IS:15185 - 2016	Absent	SND	SND		

Note: SND – Shall Not be Detectable, BDL- below Detection Limit, DL – Detection limited, N/A – Not Applicable.

Verified by

Microbiologist.

End of the report.

AUTHORISED SIGNATORY Kedar nath J Quality Manager

#### Note:

- 1) The results listed refer only to the tested samples and applicable parameters. Endorsement of products is neither inferred nor implied.
- 2) The liabilities are restricted to the invoice amount only.
- 3) Microbiological sample will be disposed after 7 days from the analysis completion date, Chemical sample will be disposed after 10 days from the analysis completion date, unless otherwise specified. Gaseous samples will be discarded after analysis.
- 4) This report is not to be reproduced wholly or in part, and cannot be used as evidence in a court of law or as any advertisement media without special permission in writing.